



Certificate of Compliance

CERTIFICATE

Applicant: Kostal Solar Electric GmbH
Hanferstraße 6
79108 Freiburg i. Br.
Germany.

Product: PV Inverter with integrated utility interface

Model: PIKO 20, PIKO 17, PIKO 15, PIKO 12, PIKO 10

Intended use:

Automatic disconnection device with three-phase mains surveillance in accordance with IEC 62116 for photovoltaic systems with three-phase parallel coupling via an inverter in the public mains supply. The automatic disconnection device is an integral part of the aforementioned inverter.

Applied standards and guidelines:

IEC 62116:2014

Test procedure of islanding prevention measures for utility-interconnected photovoltaic inverters

The safety concept of an aforementioned representative product corresponds at the time of issue of this certificate to the valid safety specifications for the specified use in accordance with regulations.

Report No: 19PP143-08_0

Certificate No: 20-220-00

Date of issue: 2020-11-05

Kiwa Primara GmbH
Gewerbstraße 28
87600 Kaufbeuren
Germany
Tel. +49 8341 99726-0
info@primara.net
www.kiwa.de



Raphael Rader
Certification Engineer