



Product Service

Attestation of Conformity

No. N8A 119275 0002 Rev. 00

Holder of Certificate: **AMERISOLAR GREEN POWER LIMITED**
ROOM 1003, 10/F, TOWER 1
LIPPO CENTRE, 89 QUEENSWAY
999077 ADMIRALTY
HONG KONG

Product: **Crystalline Silicon Terrestrial Photovoltaic (PV) Modules**
Mono-Crystalline Silicon Photovoltaic Module

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for testing and certification. For details see: www.tuvsud.com/ps-cert

Test report no.: 704062268701-00

Date, 2022-12-06

(Zhulin Zhang)

Page 1 of 2

After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. The declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.



Product Service

Attestation of Conformity

No. N8A 119275 0002 Rev. 00

Model(s):

AS-8M132-BHC-xxxW (xxx=640-675 in step of 5W)
 AS-8M120-BHC-xxxW (xxx=575-615 in step of 5W)
 AS-8M110-BHC-xxxW (xxx=520-560 in step of 5W)
 AS-8M100-BHC-xxxW (xxx=475-510 in step of 5W)
 AS-8M80-BHC-xxxW (xxx=375-410 in step of 5W)
 AS-7M144-BHC-xxxW (xxx=520-555 in step of 5W)
 AS-7M120-BHC-xxxW (xxx=430-465 in step of 5W)
 AS-7M108-BHC-xxxW (xxx=390-415 in step of 5W)
 xxx is standing for rated output power at STC

Parameters:

Construction:	Framed, double glass with Junction box, cable and connector.
Test Laboratory:	Changzhou HuaYang Inspection and Testing Technology Co., Ltd No.8 Lanxiang Road, Wujin Economic Development Zone Changzhou, Jiangsu, China.
Safety Class:	Class II
Max. System Voltage:	1500V DC
Fire Safety Class	Class A or Class C according to UL790

Tested according to:

EN IEC 61730-1:2018
 EN IEC 61730-1:2018/AC:2018-06
 EN IEC 61730-2:2018
 EN IEC 61730-2:2018/AC:2018-06